



ITEM NO.	DESCRIPTION	QTY.
1	BEAM, PULTRUDED STOCK	1
2	RIVET NUT, 1/4-20	2
3	HANDHOLE COVER	1
4	PHILLIPS SCREW, 1/4"-20x3/4"	2
5	TOP CAP	1
6	HEX SCREW, #8-18 x 1 in	2

FEATURE ORIENTATIONS			
	0°	90°	180°
HAND HOLE	X		
CABLE ENTRY	X		

NOTE: ALL HOLES DRILLED ONLY THROUGH THE FACES SPECIFIED BY 'X'



DETAIL C  
COVER ASSEMBLY  
SCALE 1 : 12



1.0	BUILD		STANDARD	
	FINISH	SMOOTH	FINISH	SMOOTH
MAXIMUM EPA PER WINDZONE				
MPH	90	100	110	120
EPA	5.6	3.2	1.4	-
				-
				-
				-
				-
				-
				-
				-

NOTES:

1. DIRECT BURIAL CLASS 1 POLE PER ASTM 4923. POLE TOP DEFLECTION SHALL NOT EXCEED 15% OF THE ABOVE GROUND HEIGHT AT MAXIMUM WIND LOADING AND MAXIMUM FIXTURE WEIGHT.
2. DESIGN CRITERIA PER AASHTO LTS-6-2013 WITH A MINIMUM SAFETY FACTOR OF 1.5 PER ANSI C136.20-2012.
3. WIND SPEEDS DEFINED AS 3 SECOND GUST PER ASCE 7-16 WITH VELOCITY CONVERSIONS PER 2018 IBC 1609.3.1.
4. EMBEDMENT BASED ON MINIMUM DEPTH RECOMMENDED BY ANSI C136.20-2012 SECTION 5.3 AND ASSUMING CLASS 2 SOIL OR BETTER WHEN LOADED AT MAXIMUM EPA.

---UNLESS OTHERWISE SPECIFIED---  
DIMENSION UNITS ARE IN FEET AND INCHES  
DIMENSIONS SHOWN ARE NOMINAL

STATE: RELEASED	2024-04-15
DRAWN: CJM	2023-06-22
CHECKED: IAB	2024-04-15
APPROVED: ARK	2024-04-15
REPLACES:	



D5SS30F00S1GXHH

G = GRAY  
A = BLACK  
F = BRONZE  
W = WHITE  
N = GREEN

ALLIANCE™

PROPRIETARY AND CONFIDENTIAL THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF GEOTEK. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF GEOTEK IS PROHIBITED.	THIRD ANGLE PROJECTION	DESCRIPTION: POLE SYSTEM, DIRECT BURIAL STANDARD DUTY, 30 FT	1421 SECOND AVE NW STEWARTVILLE, MN 55976 (800) 533-1680 www.geotek.com
CUSTOMER SIGNATURE: DATE:	-REFERENCES- alliancecompositesinc.com/warranty geotek.com/termsofconditions	SIZE: DWG. NO. B D5SS30F00S1XGXHH SCALE: 1:18	POLE COLOR: REV: 1.0 SHEET 1 OF 1